DEPARTMENT OF THE AIR FORCE
502D AIR BASE WING
JOINT BASE SAN ANTONIO

MEMORANDUM FOR ALL JBSA DRINKING WATER CUSTOMERS 23 Jun 2017

FROM: 502 ABW/CC
2080 Wilson Way
JBSA - Fort Sam Houston Texas 78234-7680

SUBJECT: Cover Letter for 2016 JBSA-Lackland Consumer Confidence Report
(PWS ID Number: 0150114)

1. The Consumer Confidence Report (CCR), also known as the Annual Water Quality Report, is required annually by the EPA Consumer Confidence Rule. The rule requires public water suppliers that serve the same people year round to provide the customers with the CCR by 1 July of each year. The CCR summarizes information regarding sources used (i.e., rivers, lakes, reservoirs, or aquifers) any detected contaminants, compliance and educational information. Specifically, your report lists what sources are used for your drinking water, what contaminants were detected during testing compared to allowable limits, and descriptions of any drinking water violations enforced by the Texas Commission on Environmental Quality during calendar year 2016.

2. There were no violations for 2016. Your water is safe to drink and meets all regulations for public water systems. All contaminant and violation details are included in the attached report.

3. If you have any questions or concerns, please visit the EPA website below or contact the Joint Base San Antonio – Lackland Bioenvironmental Engineering office at 671-7061 for assistance.
- http://water.epa.gov/lawsregs/rulesregs/sdwa/ccr/index.cfm

Heather L Pringle

HEATHER L. PRINGLE
Brigadier General, USAF
Commander

Annual Drinking Water Quality Report

TX0150114 LACKLAND AIR FORCE BASE

Annual Water Quality Report for the period of January 1 to December 31, 2016

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

LACKLAND AIR FORCE BASE is Ground Water

For more information regarding this report contact:

Name Christopher Robison

Phone 671-7061

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (___)____-____.

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

Information about Source Water Assessments

A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus source water protection strategies.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL:
http://gis3.tceq.state.tx.us/swav/Controller/index.jsp?wtrsrc=

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: http://dww.tceq.texas.gov/DWW

Source Water Name		Type of Water	Report Status	Location
1 - BLDG 1013	BLDG 1013	GW	Y	
2 - BLDG 5706	BLDG 5706	GW	Y	
4 - BLDG 4070	BLDG 4070	GW	Y	
5 - BLDG 4380	BLDG 4380	GW	Y	
6 - BLDG 9062	BLDG 9062	GW		

Lead and Copper

Definitions:
Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2016	1.3	1.3	0.76	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.

Water Quality Test Results

Definitions:	The following tables contain scientific terms and measures, some of which may require explanation.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL	million fibers per liter (a measure of asbestos)
na:	not applicable.
mrem:	millirems per year (a measure of radiation absorbed by the body)

Water Quality Test Results

NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picocuries per liter (a measure of radioactivity)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.
ppt	parts per trillion, or nanograms per liter (ng/L)
ppq	parts per quadrillion, or picograms per liter (pg/L)

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2016	1	0 - 2.1	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2016	4	0 - 9.9	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	**Collection Date**	**Highest Level Detected**	**Range of Levels Detected**	**MCLG**	**MCL**	**Units**	**Violation**	**Likely Source of Contamination**
Asbestos	06/27/2012	0.7518	0.7518 - 0.7518	7	7	MFL	N	Decay of asbestos cement water mains; Erosion of natural deposits.
Barium	2016	0.0513	0.0513 - 0.0513	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2016	0.5	0.5 - 0.5	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2016	2	0.8 - 2.14	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Radioactive Contaminants	**Collection Date**	**Highest Level Detected**	**Range of Levels Detected**	**MCLG**	**MCL**	**Units**	**Violation**	**Likely Source of Contamination**
Combined Radium 226/228	12/14/2011	1	1 - 1	0	5	pCi/L	N	Erosion of natural deposits.